

Tel.X Ni-Cd batteries

TLX 80, TLX 100, TLX 150 and TLX 180 Installation and operating instructions



1. Safety

- Never allow an exposed flame or spark near the batteries, particularly while charging.
- Never smoke while performing any operation on the battery.
- For protection, wear rubber gloves, long sleeves, and appropriate splash goggles or face shield.
- The electrolyte is harmful to skin and eyes. In the event of contact with skin or eyes, wash immediately with plenty of water. If eyes are affected, flush with water, and obtain immediate medical attention.
- Remove all rings, watches and other items with metal parts before working on the battery.
- Use insulated tools.
- Avoid static electricity and take measures for protection against electric shocks.
- Discharge any possible static electricity from clothing and/or tools by touching an earth-connected part "ground" before working on the battery.

2. Important recommendations

- Only trained and certified personnel should assemble and install Tel.X battery strings.
- Local regulations related to battery compartment ventilation (e.g. Telcordia GR-487-CORE) should be carefully observed. Saft will not be responsible for the non-observance of these regulations.
- Refer to Saft's "Tel.X batteries for telecom networks - Installation and operation manual" for complete instructions.

3. Unpacking and inspection

Tel.X batteries are shipped filled with electrolyte. A connection kit should also be included.

- Make sure all items are received by checking the material list included on each string layout sheet.
- Check for damage or electrolyte spillage. Report any abnormalities to the shipping company as well as to Saft.

4. Storage

Store the batteries in standard warehouse conditions.

- Do not store in direct sunlight or expose to excessive heat.
- Store the batteries in a temperature range of -20°C to $+35^{\circ}\text{C}$ (-4°F to $+95^{\circ}\text{F}$).

- Tel.X batteries may be stored for up to one year, without special maintenance.
- If you fully charge the battery (according to chapter 6.6), do not store the batteries for more than 2 months.

5. Preparation for transportation

- Make use of original packing cases if possible. Otherwise protect the batteries from being damaged and short-circuited.
- Transport batteries upright and secured to prevent tipping.
- For transportation over public roads, each box or pallet must carry a "hazardous material" label and any other indication required by local transport authorities.

6. Installation

6.1. General

Tel.X batteries are delivered filled with electrolyte.

- Do not top up batteries with water before, during or after initial installation.
- Batteries can be charged according to "In Service Charging" prior to installation. See chapter 6.6.
- In case of abnormal events or operating outside recommended procedures, measuring the cell **Open Circuit Voltage** (OCV) is recommended to check for normal cell condition before installation. See paragraph "Troubleshooting and abnormal operation".

6.2. Operating environment

- For tight spaces and to use a front accessible connection, make sure to install all back cable connections, first, while blocks are staged outside. To prevent, inadvertent short circuit, make sure the loose cable end is insulated.

6.3. Recommended tools

The following tools will facilitate installation:

- Insulated 10 mm socket
- Insulated torque wrench capable of 10 ± 1 N.m (96 ± 9 in.lbs)
- Multi meter (VDC)
- Crimper, 6 AWG, non-insulated lug (optional)
- Heat shrink gun (optional)

6.4. String assembly

Battery configurations vary depending on the application. A battery string layout is provided with each string.

The step by step procedures will vary with application and layout, but the following should be observed:

- Before installation, measure the OCV of each battery module and note the values. The sum of all modules will later be used to compare with battery string voltage once assembled.
- Where applicable, place trays in position to allow installation with battery modules.
- Temporarily position the battery modules in final position in accordance with the provided layout diagram. Make sure to orient the positive and negative terminals correctly.
- Use only the accessory kit parts provided.
- When a string barcode label is used, orient the module that has the affixed label so it can be accessed in its final position in the application.
- When installing a cable, torque the terminal bolts to 10 ± 1 N.m (96 ± 9 in.lbs).
- Apply generous amounts of NoOx, supplied with the accessory kit, to all terminal connections made before and after applying torque.
- For tight spaces and to use a front accessible connection, make sure to install all back cable connections, first, while blocs are staged outside. To prevent inadvertent short circuit, make sure the loose cable end is insulated.
- The modules can then be slid into place (in their trays if provided) and all front connections, cabled from the back, can subsequently be made.
- Do not at this stage connect the system's power cables.
- Connect each battery module using the accessory kit parts in accordance with the string layout diagram.
- After completing terminal connections and NoOx application, make sure to install the battery top covers.
- Battery module handles should remain in place unless it is obstructing module placement or connection. In that case remove them.

Tel.X Ni-Cd batteries

6.5. Connecting power

- Use lugs and sealable heat shrink provided in the installation kit, when necessary, for connecting power cables to the battery terminals.
- Make sure that the cables are properly secured and supported.
- Measure the battery string overall voltage and compare this with the sum of all the module OCV's measured previously. If values show a discrepancy of 1.0V or more, verify the polarity, position and connection of each module. Re-assemble as required.
- Temperature compensated voltage control is not recommended. Disengage temperature compensation circuit if activated.
- Make sure the output of the rectifier is adjusted between 1.43 to 1.45 VPC; i.e. the DC bus voltage should be between 54.4 to 55.1 VDC for 38 cells.
- Note the polarity of the battery terminals and verify the polarity of the power cables before connecting these to the battery. Look for polarity markings. **DO NOT color match.**
- Using standard practice and rectifier manufacturers recommendations as a guideline, connect the power cables to the string terminals and secure hardware: M6 Terminal Torque $10 \pm 1 \text{ N}\cdot\text{m}$ ($96 \pm 9 \text{ in}\cdot\text{lbs}$).

Table A:

Type	Nominal capacity (C ₅ Ah)	C ₅ /10 (A)	Maximum Float Current (A)
TLX 80	75	7.5	0.38
TLX 100	97	9.7	0.49
TLX 150	140	14.0	0.70
TLX 180	172	17.2	0.86

- Apply approved corrosion preventative compound on string terminals.
- If a battery must be connected to a live system (adding additional capacity), it must be necessary to charge the batteries prior to the installation to minimize the inrush current.

6.6. In Service Charging

- Constant voltage charging is recommended and should be done at 1.43 to 1.45 VPC per cell (54.4 to 55.1 VDC per 38 cell string).
- In order to re-charge fully in 24 hours, the minimum current available for each battery string should be C₅/10. See Table A for values.
- Temperature compensated voltage control is not recommended. Check with rectifier manufacturer for instructions.
- In case we need to check the IEC capacity (IEC 60623) the following procedure must be applied:
 - Make sure that the string is discharged fully and each cell is at the same SOC.
 - Charge at constant voltage with a maximum voltage set point of 1.65 V per cell and current limit of C₅/5A as mentioned in the table B:

Table B:

Type	C ₅ Ah	C ₅ /5A
TLX 80	83	16.6
TLX 100	103	20.6
TLX 150	152	30.4
TLX 180	185	37.0

- Continue charging for a minimum of 30 hours (a maximum of 1 week).
- Maximum 30 minute pause is allowed.
- Apply the load mentioned in the Table B and discharge to a cut-off of 1.0 V per cell (measured at the string terminals) and verify that the 5 hr of runtime are delivered.

7. Maintenance and Inspection

7.1. Watering

Watering is not required over the operational life of the Tel.X.

7.2. Cleaning

It is good practice to visually inspect the string during periodic site visits. Vacuuming or dusting with a soft brush is adequate if the string is dirty. A wet rag may be used, but do not use any detergent, chemicals or cleaning aids. Do not use metal brushes or hard bristles.

7.3. Periodic inspection and control

- Measure rectifier output voltage and make sure it is adjusted correctly. See paragraph "In Service Charging".
- *Re-torquing the terminal bolts is not recommended. The hardware is constructed from nickel plated steel and stainless steel which requires no torquing maintenance.*

7.4. Floating current monitoring

- When the battery is ageing, it is advisable to check the float charging current. The battery requires action if the float current is higher than **5 mA/Ah** when charging at 1.43 V/cell. See Table A for values.

A current clamp with an accuracy of ± 0.025 Amps is a way to measure the floating charge.

8. Troubleshooting and abnormal operation

It is recommended to measure the cell open circuit voltage if:

- Stored at too high or too low of temperature.
- Stored for too long of time.
- Batteries visibly OK but shipping crate excessively damaged.

To measure the cell OCV:

- Gain access to the cell terminals by removing the battery top covers. Set aside for re-use.
- Using a DMW measure each cell and check that each is **greater than or equal to 1.10 VPC per cell.**
- If a cell is below 1.10 VDC per cell, set the battery module aside and call Saft for further instructions.

9. Removal and recycling

- Make sure appropriate packing materials are available.
- Make sure each cell cap is installed to prevent spillage.
- All local laws and regulations must be respected when removing, transporting and storing used batteries.
- Contact your local Saft representative for instructions on recycling.

Saft Industrial Battery Group

12, rue Sadi Carnot
93170 Bagnole - France
Tel: +33 1 49 93 19 18
Fax: +33 1 49 93 19 64

www.saftbatteries.com

Doc N° 21778-2-0112

Data in this document is subject to change without notice and becomes contractual only after written confirmation.

Société par Actions Simplifiée
au capital de 31 944 000 €
RCS Bobigny B 383 703 873

Le Révérend Imprimeur - Printed in France - 3k



SAFT